

**ADDENDUM NO. 1**  
**9/20/19**  
**McIntosh County FEMA 2901 Project**  
**Bid #310**

**ADDENDUM**

**1. OMIT ITEMS**

**Bid Item #3 – Temporary Utility Removal and Reinstallation**

3	Temporary Utility Removal and Reinstallation	1	LS	NA	NA
---	--	---	----	----	----

Please DO NOT submit a line item price for Bid Item #3 – Temporary Utility Removal and Reinstallation. This item will be coordinated by McIntosh County staff.

**Bid Item #13 – Outfall Rip Rap**

13	Outfall RIP RAP (Incl Fabric)	1	EA	NA	NA
----	-------------------------------	---	----	----	----

Please DO NOT submit a line item price for Bid Item #13 – Outfall Rip Rap. This item is not included on this project at this time.

**QUESTIONS AND RESPONSES**

**PRE – PROPOSAL CONFERENCE - *(Sign-In Attached)***

Q1: Can McIntosh County handle the relocation of the overhead power lines during construction?

**R1: The County Staff has coordinated with Georgia Power to arrange the temporary suspension of power to the overhead lines during specified construction times. Details will be finalized with awarded bidder during the Pre-Construction Meeting.**

Q: Can the County Staff assist with the removal of tree stumps which are excavated during the clearing process?

**R: Yes. The McIntosh County Road Department will have dump trucks available to haul the excavated tree stumps to the landfill. The contractor will utilize his/her excavator to load the county trucks.**